

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Vandana
(Name of Officers with designation) from Vandana Chemist.
(Name of Department/ Office) inspected the Public Health Engineering Dept. Water Testing Laboratory FBD.
(Name & Address of the school) on 22/04/24 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 6 Month

Signature with Seal: Vandana
Public Health Engineering Department
Water Testing Lab, Faridabad:

Name : Vandana

Designation : Chemist (Quality Manager)
A.E

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department : PHED
Faridabad

To

Ashinwad Public High School
Near G.I.D. Police Chowki SGM Nagar
Faridabad.
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Memo No:- 220

Date:- 22/04/2024

Certificate
No: TC-9082

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : FBD/00110/4/2024 / Private	Sample Details	Date & Time
Sender : ASHIRWAD PUBLIC HIGH SCHOOL29969	Collected By	ASHIRWAD PUBLI...
Location : , G BLOCK S G M NAGAR NEAR 21 D POLICE CHOWKI FARI	Collection Date	15/04/2024 at 09:00
Sample Description : Drinking Water	Received at lab	15/04/2024 at 11:44
Latitude / Longitude : 77.276673 / 28.415598	Analysis Start Date	16/04/2024
	Analysis End Date	18/04/2024
	Sample Quantity	1 Litre

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	78	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
2	Total Hardness as CaCO ₃	52	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
3	Calcium as Ca	12.82	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
4	Magnesium as Mg	4.86	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
5	Iron as Fe	0.07	1.0 mg/lit.	1.0 mg/lit.	USEPA
6	Chloride as Cl	42.9	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
7	Sulphate as SO ₄	72	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO ₄ -E
8	Fluoride as F	0.46	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition 4500 F-D:
9	Nitrate as NO ₃	16.9	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D
10	pH @ 25°C	7.46	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B
11	Total Alkalinity	54	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED FARIDABAD Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 15 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

Vandana
VANDANA DESWAL, CHEMIST
DISTRICT WATER TESTING LABORATORY FARIDABAD
email:-chemist.fbad@phedharyana.gov.in

Health Department, Haryana (Faridabad)
O/o Civil Surgeon, Faridabad

Hygiene Certificate

No. HHC/fbd/2023-24/125

Date 18-7-23

Certified that the inspection of the Ashirwad..Public..High..School.
.21-D, G.-Block...K:C...Badkhal..Road, S.G.M..Nagar, ..Faridabad....
.....School has been carried out on Date...26/05/2023....The

Hygienic condition was found
satisfactory/Unsatisfactory

The above Certificate is valid till .31-03-2024. Date

Jayant

Signature with Seal:
Dy. Civil Surgeon (School Health)
Faridabad